


DIST	COUNTY	ROUTE	POST MILES TOTAL PROJECT	SHEET NO.	TOTAL SHEETS


*C. M. Dunn*  
 REGISTERED CIVIL ENGINEER  
 October 30, 2015  
 PLANS APPROVAL DATE  
 No. C59876  
 Exp. 6-30-16  
 CIVIL  
 STATE OF CALIFORNIA

THE STATE OF CALIFORNIA OR ITS OFFICERS OR AGENTS SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OR COMPLETENESS OF SCANNED COPIES OF THIS PLAN SHEET.


TO ACCOMPANY PLANS DATED \_\_\_\_\_




SHAPED BEDDING  
S = Larger than 84"




IN TRENCH



IN TRENCH



IN EMBANKMENT  
STRUCTURAL STEEL PLATE ARCHES



IN EMBANKMENT  
STRUCTURAL STEEL PLATE PIPE ARCHES  
AND VEHICULAR UNDERCROSSING

**NOTES:**

1. PIPES: 30" minimum for diameters up to and including 42" then 2/3 diameter but no more than 60" required. CORRUGATED METAL PIPE ARCHES: 30" maximum.
2. 2/3 H up to 60" maximum.
3. Slope or shore excavation sides as necessary.
4. Backfill shall be placed full width of excavation except as noted.
5. Diagrams do not apply to overside drains.
6. Dimensions shown are minimum.
7. Construction strutting of structural steel plate pipe, arches and vehicular undercrossing to be used when shown on the project plans. When shown, see Standard Plan D88A for strutting requirements.
8. Excavation below pipe and 80% relative compaction requirements for plastic pipes only.
9. D is the inside diameter (ID) of the pipe.

**LEGEND**

- STRUCTURE EXCAVATION (CULVERT)
- ROADWAY EMBANKMENT
- STRUCTURE BACKFILL (CULVERT)
- STRUCTURE BACKFILL (CULVERT) 95% RELATIVE COMPACTION
- STRUCTURE BACKFILL (CULVERT) 80% RELATIVE COMPACTION


STATE OF CALIFORNIA  
DEPARTMENT OF TRANSPORTATION

**EXCAVATION AND BACKFILL  
METAL AND PLASTIC CULVERTS**


NO SCALE

RSP A62F DATED OCTOBER 30, 2015 SUPERSEDES STANDARD PLAN A62F DATED MAY 20, 2011 - PAGE 26 OF THE STANDARD PLANS BOOK DATED 2010.


**REVISED STANDARD PLAN RSP A62F**




IN TRENCH



IN TRENCH



IN EMBANKMENT  
PIPES  
Larger than 84"



IN EMBANKMENT  
METAL AND PLASTIC PIPES AND  
CORRUGATED METAL PIPE ARCHES  
84" or Smaller

2010 REVISED STANDARD PLAN RSP A62F